

EMSL Order: 192404618 Customer ID: YNNA50 Customer PO: Project ID:

Attention:	John Ndanga	Phone:	(301) 260-0687
	Ynn & Associates, Inc.	Fax:	
	4808 Continental Drive	Received Date:	05/20/2024 08:30 AM
	Olney, MD 20832	Analysis Date:	05/20/2024
		Collected Date:	05/17/2024
Project:	POOLESVILLE HIGH SCHOOL		

Test Report: Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Appendix A to Subpart E

Sample	Location	Volume And	Area Analyzed	nalyzed Non	Asbestos Type(s)	#Structures		Analytical Sensitivity	Asbestos Concentration	
			(mm²)			≥0.5µ < 5µ	≥5µ	(S/cc)	(S/mm²)	(S/cc)
051724-T5	CAFETERIA HALLWAY	1200.00	0.0650	0	None Detected	0	0	0.0049	<15.00	<0.0049
192404618-0001										
051724-T6	HALLWAY BY ROOM 52	1200.00	0.0650	0	None Detected	0	0	0.0049	<15.00	< 0.0049
192404618-0002										
051724-T7	HALLWAY BY ROOM 49	1200.00	0.0650	0	None Detected	0	0	0.0049	<15.00	<0.0049
192404618-0003										
051724-T8	HALLWAY BY ROOM 61	1200.00	0.0650	0	None Detected	0	0	0.0049	<15.00	<0.0049
192404618-0004										
051724-T9	GLR	1200.00	0.0650	0	None Detected	0	0	0.0049	<15.00	<0.0049
192404618-0005										
051724-T10	HALLWAY BY ROOM 31	1200.00	0.0650	0	None Detected	0	0	0.0049	<15.00	<0.0049
192404618-0006										

Analyst(s)

ily Bakes

Emily Baker (6)

Bake

Emily C. Baker Asbestos Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. This report must not be used to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. Results reported in structures/cm3 are not covered by the laboratory's NVLAP accreditation. Measurement of uncertainty available upon request.

Samples analyzed by EMSL Analytical, Inc. Beltsville, MD NVLAP Lab Code 200293-0